Potter PAD300 Magnetic Test Wand — Quick Start Guide

Before Testing

• Confirm the detector is a compatible Potter PAD300 model with a magnetic test switch.

• Notify the relevant monitoring/control personnel before performing a live alarm test.

Quick Test Procedure

• Position the magnetic test wand at the detector's designated magnetic test area.

• Activate the detector's magnetic test function according to the detector's installation/manual instructions.

• Verify the detector response at the fire alarm control panel.

• After testing, remove the wand and confirm the system returns to the required normal condition.

• Testing should be performed by qualified personnel in accordance with the applicable fire alarm system procedures.

After Testing

• Confirm the detector and control panel have returned to normal operation.

• Restore any monitoring or system functions that were temporarily disabled for testing.